



INSPECTION REPORT

Report Issued: Jul 18, 2023

Inspection Result: PARTIAL PASS

Permit Number: SPRPL230305

Issuance Date: Apr 04, 2023

Property Address: 1901 CURVE PLZ;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Basecamp commercial space

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Main water supply lines, hot, cold and recirculation lines installed and under live pressure. Pipes are properly supported. Approved, Ok to insulate pipes.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us