



INSPECTION REPORT

Report Issued: Jul 14, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL210563

Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000 Holly Klein 12300 Pecos Street Westminster, CO 80234 (303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Inspected all DWV and Water lines on south end for all bath groups. DWV is under live water and approved, water lines at 60psf air held for 15 minutes, all piping per plans, properly supported and protected and approved.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us