



INSPECTION REPORT

Report Issued: Jul 19, 2023

Inspection Result: PASSED

Permit Number: SPRPL220977

Issuance Date: Jul 18, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Michael KmetzCanyon Plumbing Inc.

Contractor: Canyon Plumbing Inc. 29350 Industrial Way #210 Evergreen, CO 80439

To construct: furnish and install underground waste pipe, wall rough, plumbing fixtures, floor drains, floor sinks, drinking fountains, water pipe and insulation, water heater, mop sink, recirc pump. Gas Line.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All plumbing work is now completed and approved, final inspection approved.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us