



INSPECTION REPORT

Report Issued: Jul 19, 2023 Inspection Result: PASSED

Permit Number: SPRPL210563 Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co

80234 (719) 782-4000Holly Klein 12300 Pecos Street Wesminster, CO 80234

(303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: inspected the vent lines in the rear of the basement area, all venting approved in this area holding 6 psi for 15 minutes, properly protected and supported.

Corrections:

Sincerely,

Todd Carr Building Official tcarr@co.routt.co.us