



INSPECTION REPORT

Report Issued: Jul 19, 2023

Inspection Result: PASSED

Permit Number: SPRPL210563

Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000
Holly Klein 12300 Pecos Street Westminster, CO 80234 (303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: mechanical piping throughout the basement area is now fully approved for all chiller and heat lines to all units, contractor is going to add a few supports in a couple long span areas with the smaller 3/4 lines, full rough approval to all units.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us