



INSPECTION REPORT

Report Issued: Jul 20, 2023

Inspection Result: PASSED

Permit Number: SPRRN230707

Issuance Date: Jul 10, 2023

Property Address: 2305 MT WERNER CIR;

Applicant: Calcon Constructors, Inc

Contractor: Calcon Constructors, Inc 2270 W. BATES AVE. ENGLEWOOD, CO 80110 (720) 930-7150

To construct: Remodel existing retail space to create two separate retail spaces from what was previously one retail space. Scope of Work for Mechanical and Electrical is limited to 'Base Bid' drawing details only.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All wall framing approved, please leave 1 side open on walls that have electrical until inspection is complete.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us