



INSPECTION REPORT

Report Issued: Jul 26, 2023

Inspection Result: PASSED

Permit Number: SPREL230656

Issuance Date: Jun 05, 2023

Property Address: 2315 APRES SKI WAY;

Applicant: BLACK LAB ELECTRICAL LLC

Contractor: BLACK LAB ELECTRICAL LLC P O BOX 772768 STEAMBOAT SPRINGS, CO
80477 (970) 761-0458

To construct: New in ground pool and 2 hot tubs

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Final electrical approved note electrical contractors scope of work limited to equipotential bonding and emergency stop buttons for hot tubs

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us