



INSPECTION REPORT

Report Issued: Jul 26, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH221078

Issuance Date: Aug 03, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Griff Osman

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New Mechanical for SPRNR220115

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Locker room bathrooms have heaters and exhaust ducts installed. Pipes are properly supported and sealed. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us