



# INSPECTION REPORT

**Report Issued:** Jul 26, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL210563

**Issuance Date:** Nov 08, 2021

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** MTech Mechanical Technologies Group

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000 Holly Klein 12300 Pecos Street Westminster, CO 80234 (303) 650-4000

**To construct:** Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** TWV and water lines for bathrooms in locker room completed to plants. All pipes properly supported and protected. TWV test good at five psi water line test good at 100psi. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us