



INSPECTION REPORT

Report Issued: Jul 31, 2023

Inspection Result: **FAILED**

Permit Number: SPRPL220761

Issuance Date: Jun 08, 2022

Property Address: 1901 CURVE PLZ;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Basecamp affordable Housing Plumbing(Undergrounds, Rough and Trim, gas

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: See corections and reinspect.

Corrections:

- 1 1. Make sure gas meter is 4' horizontally from vent terminations
2. Cut out spray foam around vent pipe and replace with non combustibile rock wool
3. Install condensate treatment and piping to floor drain

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us