



INSPECTION REPORT

Report Issued: Sep 12, 2023

Inspection Result: PASSED

Permit Number: SPRMH230856

Issuance Date: Jul 12, 2023

Property Address: 2305 MT WERNER CIR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: Demo per floor plans and notes, Ductwork modifications, Add (4) thermostats, (1) GRDs.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: rough inspection approved, all main trunk lines are sealed, all flex lines are ran and connected to diffusers, we will need you to pull insulation on flex lines up tight to main trunks and strap them yet upon the finish work.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us