



# INSPECTION REPORT

**Report Issued:** Sep 12, 2023

**Inspection Result:** PASSED

**Permit Number:** SPRMH230856

**Issuance Date:** Jul 12, 2023

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Holly Klein

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** Demo per floor plans and notes, Ductwork modifications, Add (4) thermostats, (1) GRDs.

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** rough inspection approved, all main trunk lines are sealed, all flex lines are ran and connected to diffusers, we will need you to pull insulation on flex lines up tight to main trunks and strap them yet upon the finish work.

Final inspection is approved minus the strapping of flex lines at boots off main trunk lines, we will inspect this item under the main building permit upon final.

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us