



INSPECTION REPORT

Report Issued: Sep 25, 2023

Inspection Result: PASSED

Permit Number: SPREL221611

Issuance Date: Oct 31, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: CENTRAL ELECTRIC, LLC

Contractor: CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487
(970) 846-8379

To construct: Preview Chair Lift
New operator cabin for Preview Chair Lift.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Final for relocating lighting controls from preview to Christy approved

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us