



INSPECTION REPORT

Report Issued: Sep 26, 2023

Inspection Result: PASSED

Permit Number: SPRMH230620

Issuance Date: May 25, 2023

Property Address: 1855 SKI TIME SQUARE DR, UNIT:401;

Applicant: J & I Plumbing and Heating Services LLC

Contractor: J & I Plumbing and Heating Services LLC 1664 Yampa Ave Craig, CO 81325

To construct: 2 mini split heads an additional 3 split heads added

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Last remaining AC lines tested and held pressure for 15 minutes, all rough inspections now approved for mini splits

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us