



# INSPECTION REPORT

**Report Issued:** Oct 04, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPREL230514

**Issuance Date:** May 11, 2023

**Property Address:** 1901 CURVE PLZ;

**Applicant:**

**Contractor:** Tegra Electric 8493 S Dudley St., 203-B Wheat Ridge, CO 80033 (720) 595-7898

**To construct:** Electrical for commercial addition/remodel

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial final approved floor receptacles in golf shop will need reinspection, ceiling in bicycle bathroom will need reinspection. Note: locker Hall West end has no light per plan.

**Corrections:**

Sincerely,

Tom Cook  
Electrical Plan Reviewer/Inspector  
tcook@co.routt.co.us