



# INSPECTION REPORT

**Report Issued:** Oct 05, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL220761

**Issuance Date:** Jun 08, 2022

**Property Address:** 1901 CURVE PLZ;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** Basecamp affordable Housing Plumbing(Undergrounds, Rough and Trim, gas

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** All units approve minus two minor corrections in unit 109 and 115.

## **Corrections:**

- 1 Building Department Corrections to be Completed
  1. Unit 109 kitchen sink has a possible factory lead at the water shut off valve under the sink, small but dripping.
  2. Unit 115 first bathroom on left has a tub spout out to far from wall and is wobbly.

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us