



# INSPECTION REPORT

**Report Issued:** Oct 06, 2023

**Inspection Result:** PASSED

**Permit Number:** SPRMH221672

**Issuance Date:** Nov 09, 2022

**Property Address:** 1859 RIVER QUEEN LN;

**Applicant:** HOT STUFF HEARTH & HOME

**Contractor:** HOT STUFF HEARTH & HOME 1625 MID VALLEY DR #3 STEAMBOAT SPGS, CO  
80487 (970) 879-7614

**To construct:** Supreme Novo 18 Free Standing WB Stove

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** rough approved with unit set, chimney ran through roof and strapped back to roof for support, and combustion air ran. Call back for final once unit is ready to burn wood.

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us