



# INSPECTION REPORT

**Report Issued:** Oct 12, 2023

**Inspection Result:** PASSED

**Permit Number:** SPRPL230305

**Issuance Date:** Apr 04, 2023

**Property Address:** 1901 CURVE PLZ;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** Basecamp commercial space

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** DWV and ejector pit installed for 1 floor drain and 1 floor sink. DWV test is good at 5 psi. Approved to cover

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us