



INSPECTION REPORT

Report Issued: Oct 13, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRSF220630

Issuance Date: Sep 07, 2022

Property Address: 1851 RIVER QUEEN LN;

Applicant: Saltbox Custom Homes Inc

Contractor: Saltbox Custom Homes Inc 5 Murray Rd. Unit B4 Edwards, CO 81632 (970) 376-7258

To construct: new home

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All foundation walls approved to enclose, all bar tied per plans with either 18' oc or 12" oc for tall walls, ensure bar clearances are met once enclosed.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us