



# INSPECTION REPORT

**Report Issued:** Oct 19, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPREL231143

**Issuance Date:** Aug 21, 2023

**Property Address:** 1857 RIVER QUEEN LN;

**Applicant:** STEAMBOAT ELECTRIC

**Contractor:** STEAMBOAT ELECTRIC P.O. BOX 771314 STEAMBOAT SPGS, CO 80477 (970) 761-1175

**To construct:** New construction, taking over from Ridgeline Electric, trim - out.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** partial final approved for TCO. 1 additional receptacle is needed between kitchen sink and range for final.

**Corrections:**

Sincerely,

Tom Cook  
Electrical Plan Reviewer/Inspector  
tcook@co.routt.co.us