



# INSPECTION REPORT

**Report Issued:** Oct 23, 2023

**Inspection Result:** **FAILED**

**Permit Number:** SPREL220316

**Issuance Date:** Mar 29, 2022

**Property Address:** 1859 RIVER QUEEN LN;

**Applicant:**

**Contractor:** STEAMBOAT ELECTRIC P.O. BOX 771314 STEAMBOAT SPGS, CO 80477 (970)  
761-1175

**To construct:** New Construction Residential

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Conduits require 18 in of cover slightly over 6 in of cover in places

**Corrections:**

Sincerely,

Tom Cook  
Electrical Plan Reviewer/Inspector  
tcook@co.routt.co.us