



# INSPECTION REPORT

**Report Issued:** Oct 23, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH231521

**Issuance Date:** Oct 18, 2023

**Property Address:** 1901 CURVE PLZ;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** basecamp commerical space ,Forced Air System,Furnace (0-100,000 BTU)Refrigeration Unit

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Inspected 6 line sets for AC units, on unit at main door at ground level, 4 units on lower roof pit, and 1 unit in upper roof pit, all held 400psf in lines and approved.

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us