



# INSPECTION REPORT

**Report Issued:** Oct 24, 2023

**Inspection Result:** PASSED

**Permit Number:** SPRSF220630

**Issuance Date:** Sep 07, 2022

**Property Address:** 1851 RIVER QUEEN LN;

**Applicant:** Saltbox Custom Homes Inc

**Contractor:** Saltbox Custom Homes Inc 5 Murray Rd. Unit B4 Edwards, CO 81632 (970) 376-7258

**To construct:** new home

On this day we have inspected your construction for **Foundation Drain Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Drain complete with gravel, wrap and cleanouts. OK to backfill

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us