



INSPECTION REPORT

Report Issued: Oct 24, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH231521

Issuance Date: Oct 18, 2023

Property Address: 1901 CURVE PLZ;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: basecamp commerical space ,Forced Air System,Furnace (0-100,000 BTU)Refrigeration Unit

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All HVAC equipment and duct work in commercial spaces installed to approved plans. All equipment installed in proper location and properly supported except 2 areas discussed. Add support for duct in mani commercial space and in mechanical room. Install missing grilles when they arrive on site. All equipment is properly functioning. Will need TAB report. Good for TCO

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us