



# INSPECTION REPORT

**Report Issued:** Nov 01, 2023

**Inspection Result:** PASSED

**Permit Number:** SPRMU230307

**Issuance Date:** Jul 21, 2023

**Property Address:** 1901 CURVE PLZ;

**Applicant:** May Riegler Properties, LLC (Gaby & Kevin Riegler)

**Contractor:** Steamboat Building Company, LLC 1195 BANGTAIL WAY, PO Box 774165  
STEAMBOAT SPRINGS, CO 80487 (832) 457-6095

**To construct:** Building 1 of Basecamp Townhomes. Includes seven (7) individual townhome units.

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Foundation forms complete. All rebar installed is properly sized and spaced. All void forms installed. All rebar clearances are good. Approved. Good to pour

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us