



INSPECTION REPORT

Report Issued: Nov 03, 2023

Inspection Result: NOT READY

Permit Number: SPRMH231602

Issuance Date: Nov 02, 2023

Property Address: 1716 COPPER RIDGE SPUR;

Applicant: LFM MECHANICAL

Contractor: LFM MECHANICAL P.O. BOX 882331 STEAMBOAT SPRINGS, CO 80488 (970) 819-5115

To construct: Install heating system

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: wrong inspection type

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us