



INSPECTION REPORT

Report Issued: Nov 16, 2023

Inspection Result: NOT READY

Permit Number: SPREL220316

Issuance Date: Mar 29, 2022

Property Address: 1859 RIVER QUEEN LN;

Applicant:

Contractor: STEAMBOAT ELECTRIC P.O. BOX 771314 STEAMBOAT SPGS, CO 80477 (970)
761-1175

To construct: New Construction Residential

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Recall when de-icing circuit breakers are installed and engraved placards are on both services

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us