

**NORTHWEST COLORADO CONSULTANTS, INC.
FIELD REPORT**

Project: Richey Live-Work Units **Project No.:** 21-12512
Location: Steamboat Springs, CO **Report No.:** 2-HP
Client: Adam Richey

Date: 8/15/23
Time: 11.0
Mileage: 2
Engr. /Tech: JE/CR

Work Performed:

As requested, we visited the project site on today's date to observe the helical screw pile installation operations. The pile installation contractor, SSX, installed seventeen (17) 2 7/8-inch diameter double helix screw piles. The piles are provided by Pier Tech and include 8 and 10-inch helices.

A summary table of the piles completed on this date is attached.

Remarks:

Based on our observations and measurements, the piles completed on this date appeared to be installed to the required torque.

Verbal Discussions:

Derrick of SSX was aware of today's observations and measurements.