

**NORTHWEST COLORADO CONSULTANTS, INC.**  
**FIELD REPORT**

**Project:** Richey Live-Work Units **Project No.:** 21-12512  
**Location:** Steamboat Springs, CO **Report No.:** 3-HP  
**Client:** Adam Richey

**Date:** 8/16/23  
**Time:** 5.0  
**Mileage:** 2  
**Engr. /Tech:** CR

**Work Performed:**

As requested, we visited the project site on today's date to observe the helical screw pile installation operations. The pile installation contractor, SSX, installed five (5) 2 7/8-inch diameter double helix screw piles. The piles are provided by Pier Tech and include 8 and 10-inch helices.

A summary table of the piles completed on this date is attached.

**Remarks:**

Based on our observations and measurements, the piles completed on this date appeared to be installed to the required torque.

**Verbal Discussions:**

Derrick of SSX was aware of today's observations and measurements.