



INSPECTION REPORT

Report Issued:	Jan 29, 2024	Inspection Result:	PARTIAL I	PASS
----------------	--------------	--------------------	-----------	------

Permit Number: SPRPL240035
Issuance Date: Jan 10, 2024
Property Address: 2968 VILLAGE DR;

Applicant: CROSS MOUNTAIN PLMB & HEAT

Contractor: CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,, CO

80477 (970) 819-4276

To construct: New construction DWV, water piping, gas piping, and fixture set.

South Building 2968 Village dr

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: In slab drains, holding 6 psi.

Corrections:

Sincerely,

Jeff Yeiser Inspector jyeiser@co.routt.co.us