



# INSPECTION REPORT

**Report Issued:** Feb 02, 2024

**Inspection Result:** PASSED

**Permit Number:** SPRMH240032

**Issuance Date:** Jan 10, 2024

**Property Address:** 3367 APRES SKI WAY;

**Applicant:** ALDRICH BUILT

**Contractor:** ALDRICH BUILT PO BOX 882943 STEAMBOAT SPRINGS, CO 80488 (970) 819-2475

**To construct:** We are creating a Fire Separation between a lower level SDU and Upper level main dwelling unit.

This consists of inline mechanical fire dampers placed at all ducts in the lower level. There will be (5) 6" and (1) 8" fire dampers in the basement. The (5) 6" dampers will be installed at each air supply register in the basement. The one 8" damper will be installed at the air intake for the furnace. These will keep any fire from using the ducts as a path way to upstairs.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Five fire dampers installed on supply side and one installed in return. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us