



# INSPECTION REPORT

**Report Issued:** Feb 13, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRPL240116

**Issuance Date:** Feb 07, 2024

**Property Address:** 405 ANGLERS DR;

**Applicant:** Immaculate Plumbing LLC

**Contractor:** Urban Remodz LLC 3550 S Downing St Englewood, CO 80113

**To construct:** Adding rinse staton with two shower heads and a drain. Also adding 3 floor drains, 4 hvac evac fans possibly 5.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Under slab DWV installed and passed test with ten foot head of water. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us