



INSPECTION REPORT

Report Issued: Feb 14, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240116

Issuance Date: Feb 07, 2024

Property Address: 405 ANGLERS DR;

Applicant: Immaculate Plumbing LLC

Contractor: Urban Remodz LLC 3550 S Downing St Englewood, CO 80113

To construct: Adding rinse staton with two shower heads and a drain. Also adding 3 floor drains, 4 hvac evac fans possibly 5.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Shower pan installed and held water for test duration. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us