



INSPECTION REPORT

Report Issued: Mar 18, 2024

Inspection Result: PASSED

Permit Number: SPRAD230901

Issuance Date: Oct 03, 2023

Property Address: 1495 MARK TWAIN LN;

Applicant: GARCIA CONSTRUCTION LIMITED

Contractor: GARCIA CONSTRUCTION LIMITED 1153 OAK STREET STEAMBOAT SPRINGS,
CO 80477 (970) 757-3250

To construct: Extending the Garage for 7' add slider door on the upper floor and new deck

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Steel framing welded and bolted. Rafters correct and hangered/clipped. Glue lams in place per plan. Ok to insulate.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us