



INSPECTION REPORT

Report Issued: Mar 26, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH231639

Issuance Date: Nov 09, 2023

Property Address: 1851 RIVER QUEEN LN;

Applicant: Isidro Quezada

Contractor: IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

To construct: In floor heating system for home at 1851 River Queen Lane.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Hydronic tubing properly stapled to subfloor on main level and passed test of 100psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us