



# INSPECTION REPORT

**Report Issued:** Mar 27, 2024

**Inspection Result:** PASSED

**Permit Number:** SPRGS240214

**Issuance Date:** Mar 14, 2024

**Property Address:** 1800 BURGESS CREEK RD;

**Applicant:** HANSEN MECHANICAL SERVICES LLC

**Contractor:** HANSEN MECHANICAL SERVICES LLC 27714 SILVER SPUR ST. STEAMBOAT  
SPGS, CO 80487-8405 (970) 734-4009

**To construct:** Atmos Energy pulled the gas meter because the property was vacant for a year. The new owners are wanting to get the gas turned back on and need it pressure tested and green tagged. This will be a pressure test of the existing gas line. No modifications are being made.

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Test of existing gas line that had meter removed. Gas line test is good at 15psi. Approved, green tag issued.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us