



INSPECTION REPORT

Report Issued: Apr 11, 2024

Inspection Result: PASSED

Permit Number: SPRPL231585

Issuance Date: Oct 27, 2023

Property Address: 1716 COPPER RIDGE SPUR;

Applicant: LFM MECHANICAL

Contractor: LFM MECHANICAL P.O. BOX 882331 STEAMBOAT SPRINGS, CO 80488 (970)
819-5115

To construct: Plumbing

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV and water lines have been installed, supported and protected correctly. Pressure tests good for 15 minutes. Rough plumbing approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us