



INSPECTION REPORT

Report Issued: Apr 11, 2024

Inspection Result: PASSED

Permit Number: SPRMH231602

Issuance Date: Nov 02, 2023

Property Address: 1716 COPPER RIDGE SPUR;

Applicant: LFM MECHANICAL

Contractor: LFM MECHANICAL P.O. BOX 882331 STEAMBOAT SPRINGS, CO 80488 (970) 819-5115

To construct: Install heating system

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Staple up hydronic lines, gas lines and ducts for ERV and bath fans have been installed, supported and protected correctly. Pressure tests good for 15 minutes. Rough mechanical approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us