



INSPECTION REPORT

Report Issued: Apr 22, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: SPRNR231281

Issuance Date: Jan 22, 2024

Property Address: 3300 S LINCOLN AVE;

Applicant: Maurer Construction LLC

Contractor: Maurer Construction LLC 2621 Connery Way Missoula, MT 59808 (406) 542-6565

To construct: New construction of a 63,527 GSF 4-story, 90 unit hotel
STOP WORK ORDER generated on 04/10/2024 by username 'Todd Carr'.
STOP WORK ORDER removed on 04/15/2024 by username 'Malea Michael-Ferrier'.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 6" perimeter walls, all #5, verticals 16" oc , horizontal 12" oc , no lap or spacing issues, Ok to pour.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us