



INSPECTION REPORT

Report Issued:	May 02, 2024	Inspection Result:	PASSED
----------------	--------------	--------------------	---------------

Permit Number: SPRMH240032 Issuance Date: Jan 10, 2024

Property Address: 3367 APRES SKI WAY;

Applicant: ALDRICH BUILT

Contractor: ALDRICH BUILT PO BOX 882943 STEAMBOAT SPRINGS, CO 80488 (970) 819-

2475

To construct: We are creating a Fire Separation between a lower level SDU and Upper level

main dwelling unit.

This consists of inline mechanical fire dampers placed at all ducts in the lower level. There will be (5) 6" and (1) 8" fire dampers in the basement. The (5) 6" dampers will installed at each air supply register in the basement. The one 8" damper will be installed at the air intake for the furnace. These will keep any

fire from using the ducks as a path way to upstairs.

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Allm work completed to scope of permit and operational. Approved

Corrections:

Sincerely,

Ron Norton Inspector rnorton@co.routt.co.us