



# INSPECTION REPORT

**Report Issued:** May 30, 2024

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL240603

**Issuance Date:** May 29, 2024

**Property Address:** 3300 S LINCOLN AVE;

**Applicant:** Scott Sypniewski

**Contractor:** Scott Sypniewski, LLC 8045 Noble Fir Court Colorado Springs, CO 80927

**To construct:** plumbing for hotel

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Under slab DWV and grease interceptor complete front of building, additional drains to be completed. Two stacks holding 5 psi

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us