



INSPECTION REPORT

| Report Issued: | Jun 07, 2024 Ir | spection Re | esult: | PARTIAL I | PASS |
|-------------------|-------------------------------|---------------|----------|---------------|-------|
| Permit Number: | SPRPL240603 | | | | |
| Issuance Date: | May 29, 2024 | | | | |
| Property Address: | 3300 S LINCOLN AVE; | | | | |
| Applicant: | Scott Sypniewski | | | | |
| Contractor: | Scott Sypniewski, LLC 8045 No | ble Fir Court | Colorado | o Springs, CO | 80927 |
| To construct: | plumbing for hotel | | | | |

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All DWV underslab now approved with final branch holding 6psi for 15 mintues

Corrections:

Sincerely,

Todd Carr Building Official tcarr@co.routt.co.us