



INSPECTION REPORT

Report Issued: Jun 12, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: SPRRN240314

Issuance Date: May 20, 2024

Property Address: 385 ANGLERS DR;

Applicant: Mammoth Construction LLC

Contractor: Mammoth Construction LLC 18712 E. Prentice Drive Centennial, CO 80015
(970) 319-6943

To construct: Build out of a new office within the existing structure

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Walls of existing space removed and new office walls framed per plans. Will need plumbing permit for plumbing removal and electrical permit for relocation of switches and outlets.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us