



INSPECTION REPORT

Report Issued: Jun 26, 2024

Inspection Result: PARTIAL PASS

Permit Number: SPRPL240545

Issuance Date: May 17, 2024

Property Address: 322 RIVERVIEW WAY;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building B New Plumbing install

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 8" sanitary main approved into the building from the double cleanout, held 5 psi for 15 minutes and runs all the way to the middle of the building where it connects to the 6" lines going both directions. Proper compaction and sloped properly.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us