



INSPECTION REPORT

Report Issued: Jun 28, 2024

Inspection Result: PARTIAL PASS

Permit Number: SPRPL240545

Issuance Date: May 17, 2024

Property Address: 322 RIVERVIEW WAY;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building B New Plumbing install

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All DWV underground piping is passed this morning, including set of Separator tank and connections. All piping bedded and supported and sloped properly, held 5 1/2 psi for 15 minutes. all future underslab will be done after footings and walls are completed.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us