



# INSPECTION REPORT

**Report Issued:** Jul 08, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRRN240314

**Issuance Date:** May 20, 2024

**Property Address:** 385 ANGLERS DR;

**Applicant:** Mammoth Construction LLC

**Contractor:** Mammoth Construction LLC 18712 E. Prentice Drive Centennial, CO 80015  
(970) 319-6943

**To construct:** Build out of a new office within the existing structure

On this day we have inspected your construction for **Drywall Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Office area, fire rated assemblies intact, interior walls 1/2" drywall installed, ok to finish. Fire rated wall where plumbing was capped, to be completed

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us