



# INSPECTION REPORT

**Report Issued:** Jul 08, 2024

**Inspection Result:** PASSED

**Permit Number:** SPRPL240712

**Issuance Date:** Jun 13, 2024

**Property Address:** 1855 SKI TIME SQUARE DR;

**Applicant:** MOUNTAIN HIGH MECHANICAL

**Contractor:** MOUNTAIN HIGH MECHANICAL 2570 Copper Ridge Dr Unit A4 Steamboat Springs, CO 80487

**To construct:** New plumbing for new shower, POU water heater, water fountain and mop sink.  
Drains and water lines.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Water lines extended for shower and bottle filler, drains holding 7 psi, water is live.

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us