



INSPECTION REPORT

Report Issued: Jul 16, 2024

Inspection Result: NOT READY

Permit Number: SPRNR230776

Issuance Date: Jul 03, 2023

Property Address: 1716 COPPER RIDGE SPUR, UNIT:C2;

Applicant: Richey Construction

Contractor: Richey Construction PO Box 775272 Steamboat Springs, CO 80477 (970) 846-1168

To construct: New Duplex style Live Work Unit 2

See SPRNR230582 for Unit 1

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Not final building: Windows needing tempered glass are now installed in upstairs near living room closet.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us