



INSPECTION REPORT

Report Issued: Jul 16, 2024

Inspection Result: PASSED

Permit Number: SPRMH231601

Issuance Date: Nov 02, 2023

Property Address: 1716 COPPER RIDGE SPUR, UNIT:C1;

Applicant: LFM MECHANICAL

Contractor: LFM MECHANICAL P.O. BOX 882331 STEAMBOAT SPRINGS, CO 80488 (970) 819-5115

To construct: Install heating system

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New boiler has been installed and vented correctly with all clearances met. Zones labeled and condensate drained and is ready to operate. Green tag issued.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us