



INSPECTION REPORT

Report Issued: Jul 17, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240546

Issuance Date: May 17, 2024

Property Address: 355 RIVERVIEW WAY;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building E New Plumbing Install

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Inspected remaning sanitary line for drains in garage to the intake side of the separator, and inspected all deep Storm Drains down the entire middle of the building, there will be one storm drain inspection left that heads towards the river off the 8" main in the middle, then all deep underground SS and ST lines will be completed. Held 5psi for 15 minutes, proper size, slope and compaction.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us